

CERTIFICATE OF CONFORMITY

For Product Certification Scheme: Type 5

Product : Fire Rated Door
Brand : SH-4
Model : SH-4
Country of Origin : Singapore
Product Details : Uninsulated, single-acting, double leaf steel door with vision panel
Integrity: 240 mins
Refer to Appendix for hardware use

which has complied with the requirements of the scheme based on the following:

STANDARD(S)	TEST REPORT(S)
SS 332: 2007 Clause 4	Refer to Appendix



Sze Thiam Siong (Mr)
General Manager
SETSCO Services Pte Ltd
18 Teban Gardens Crescent
Singapore 608925

Certificate No
FSP-2018-0642

Date of Issue
19/06/2018

Date of Expiry
26/05/2023



This Certificate is part of full report and should be read in conjunction with it. This Certificate remains the property of SETSCO Services Pte Ltd (SETSCO) and shall be returned upon request. The use of this Certificate is subjected to the terms and conditions of the SETSCO Product Certification Scheme. The manufacturer is solely responsible for the compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking it at www.setsco.com



The use of the SAC accreditation mark indicates accreditation in respect of those activities covered by the accreditation certificate number PD-2010-10.